

CERTIFICATE OF COMPLIANCE

Certificate Number R40151
Report Reference R40151-20210820
Date 2021-September-02

Issued to: TEC International LLC
26695 Eckel Rd, Suite 3
PERRYSBURG OH, 43551 US

This is to certify that representative samples of FIRE-RESISTIVE CABLE
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 2196 and ULC S139 - Fire Test for Circuit Integrity of Fire-Resistive Power, Instrumentation, Control and Data Cables.

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number R40151
Report Reference R40151-20210820
Date 2021-September-02

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

MICC Brand Type MI (Mineral Insulated - Copper Sheathed) for use in System No. FHIT.1083C FRR 2h, Maximum 600 VAC (line-to-line) when installed in accordance with manufacturer's installation instructions MMC MI dated Nov 2020.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

